



-Volumul de aer exhaustat 32.000 mc/h

13	Piesa protectie cod	1		
12	Cot 45/D600	2		
11	Cot 90/D600	2		
10	Teava D250	---	L=25m	
9	Teava D600	---	L=25m	
8	Confuzor 450/600	2		
7	Teava D450	---	L=14m	
6	Cot 30/D250	6		
5	Cot 90/D250	19		
4	Cot 45/D250	4		
3	Clapeta de reglaj	16		
2	Piesa de trecere	16		
1	Nota de aspiratie	16		
Poz	Denumire	Nr. deserv	Observati	Masa neta
	Protectia la intrare			2,359-5,0
-ECHIPAMENTE SI INSTALATI & GALVANIZARE s.r.l - CPA srl				INSTALATIE DE VENTILATIE